



**Installation:** hazardous areas - Zone 1 / 2 (Gases) - Zone 21 / 22 (Dusts)  
**Classification:** Group II - Category 2G 2D



**REFERENCE STANDARDS**

**Directive 2014/34/EU**

EXECUTION	⊗ II 2 G Ex d / Exe / Exia IIC Gb ⊗ II 2 D Ex tb IIIC Db
RULES OF COMPLIANCE	EN/IEC 60079-0; EN/IEC 60079-1; EN/IEC 60079-7; EN/IEC 60079-31
EC Type-Examination Certificate	INERIS 09 ATEX 0028X
PROTECTION DEGREE	IP66 or IP66/68
AMBIENT TEMPERATURE	-40°C ÷ +90°C (Rubber rings EPDM-60) -60°C ÷ +180°C (Rubber rings SILICON)
OTHER AVAILABLE CERTIFICATES	IECEX: IECEX INE 11.0017X INMETRO: CEPEL 12.2175X EAC: TC RU C-IT.BH02.B.00587 (-75°C ÷ +180°C) RINA: ELE139017CS004 RUSSIAN MARINE CERTIFICATE (RMRS): 13.03518.315 CCOE-PESO: P405709/1

**Mechanical characteristics**

Body / cap	OT-58 marine brass (ON) - AISI-316L stainless steel (IX) marine grade copper free aluminium (on project request only)
Finishes	full nickel plating treatment (brass material only)
Rubber rings	EPDM rubber 50-60 shore hardness (standard supply) Silicon rubber 60 shore hardness (on demand only)
O-ring	silicon rubber - 60 shore hardness
Skid washer	nylon 6.0
Chamber for sealing	OT-58 marine brass ("R" version only)

**Applications**

For unarmoured cables only
Single compression type suitable for indoor and outdoor use
Single compression - on cable (inner sealing)
Sealing with proper resin into "chamber of sealing" (on barrier type version "R" only)



**On Request Accessories:**

- Locknuts, Gaskets, PVC Shrouds, Earthing Tags, Sealing (See DL-NW-PTD-ET bulletin)

**Cable gland selection table**

CODE (1)	SIZE	ENTRY THREAD SIZE				INNER SHEATH DIA.		HEXAGON [mm]	MATERIAL			
		METRIC (2)	NPT (2)	ISO 228 (2)	min [mm]	max [mm]	(3)					
PNA# PNA-R#	00*	ISO-M16	M	3/8"NPT	N	3/8"	G	4,0	7,0	24,0	NICKEL PL.BRASS	ON
								7,0	10,0		STAINLESS STEEL	IX
PNA# PNA-R#	01	ISO-M20	M	1/2"NPT	N	1/2"	G	5,5	8,0	32,0	NICKEL PL.BRASS	ON
								8,0	10,5		STAINLESS STEEL	IX
								10,5	13,0			
PNA# PNA-R#	02	ISO-M25	M	3/4"NPT	N	3/4"	G	10,5	13,0	36,0	NICKEL PL.BRASS	ON
								13,0	15,5		STAINLESS STEEL	IX
								15,5	18,0			
PNA# PNA-R#	03	ISO-M32	M	1"NPT	N	1"	G	15,0	18,0	45,0	NICKEL PL.BRASS	ON
								18,0	21,0		STAINLESS STEEL	IX
								21,0	24,0			
PNA# PNA-R#	04	ISO-M40	M	1 1/4"NPT	N	1 1/4"	G	21,0	24,0	53,0	NICKEL PL.BRASS	ON
								24,0	27,0		STAINLESS STEEL	IX
								27,0	30,0			
PNA# PNA-R#	05	ISO-M50	M	1 1/2"NPT	N	1 1/2"	G	24,0	27,0	61,0	NICKEL PL.BRASS	ON
								27,0	30,0		STAINLESS STEEL	IX
								30,0	33,0			
								33,0	36,0			
PNA# PNA-R#	06	ISO-M63	M	2"NPT	N	2"	G	36,0	39,0	71,0	NICKEL PL.BRASS	ON
								39,0	42,0		STAINLESS STEEL	IX
								42,0	45,0			
PNA# PNA-R#	07	ISO-M75	M	2 1/2"NPT	N	2 1/2"	G	42,0	45,0	84,0	NICKEL PL.BRASS	ON
								45,0	48,0		STAINLESS STEEL	IX
								48,0	51,0			
								51,0	54,0			
PNA# PNA-R#	08	ISO-M90	M	3"NPT	N	3"	G	52,0	56,0	101,0	NICKEL PL.BRASS	ON
								56,0	59,0		STAINLESS STEEL	IX
								59,0	62,0			
								62,0	65,0			
								65,0	68,0			
PNA# PNA-R#	09	ISO-M100	M	4"NPT	N	4"	G	68,0	74,0	126,0	NICKEL PL.BRASS	ON
								74,0	80,0		STAINLESS STEEL	IX
								80,0	86,0			
								86,0	92,0			

**CABLE GLAND ORDERING EXAMPLES**

PNA#	01	M	ON	= PNA#01MON (NON-BARRIER CABLE GLAND NICKEL PLATED BRASS ISO-M20 THR.)
PNA#	03	N	IX	= PNA#03NIX (NON-BARRIER CABLE GLAND STAINLESS STEEL 1/2"NPT THR.)

**\*NOTE:** 00 SIZE WITH ISO-M20 OR 1/2"NPT - 1/2"ISO-228 BODY, ON REQUEST

**LEGEND**

(1)	CABLE GLAND TYPE/MODEL	PNA# = NON-BARRIER CABLE GLAND - PNA-R# = BARRIER CABLE GLAND
(2)	THREADING	M = ISO METRIC pitch 1,5mm - N = NPT (ANSI/ASME B1.20.1) - G = ISO-228
(3)	CABLE GLAND MATERIAL	ON = NICKEL PLATED MARINE BRASS - IX = AISI-316L STAINLESS STEEL

**PNA DIMENSIONAL**

1	BODY
2-3-4	INNER SEALING RING FOR NOT ARMOURED CABLE
5	PRESS RING
6	GLAND NUT
7	O-RING (ONLY FOR METRICAL)
8	*CHAMBER FOR SEALING ("R" VERSION ONLY)

\* Chamber will be filled with sealing when cable gland is completely assembled.

**REMARK:**

Due to the development of the national and international specifications and of the technology, the above technical characteristics showed on this bulletin can be considered as binding on our confirmation only.

