Installation: hazardous areas - Zone 1 / 2 (Gases) - Zone 21 / 22 (Dusts)
Classification: Group II - Category 2G 2D

REFERENCE STANDARDS	
Directive 2014/34/EU	
EXECUTION	⟨Ex⟩ II 2 G Ex d / Exe / Exia IIC Gb ⟨Ex⟩ II 2 D Ex tb IIIC Db
RULES OF COMPLIANCE	EN/IEC 60079-0; EN/IEC 60079-1; EN/IEC 60079-7; EN/IEC 60079-31
EC Type-Examination Certificate	INERIS 09 ATEX 0028X
PROTECTION DEGREE	IP66 or IP66/68
AMBIENT TEMPERATURE	-40°C ÷ +90°C (Rubber rings EPDM-60) -60°C ÷ +180°C (Rubber rings SILICON)
OTHER AVAILABLE CERTIFICATES	IECEx: IECEx INE 11.0017X
	INMETRO: CEPEL 12.2177X
	EAC: TC RU C-IT.BH02.B.00587 (-75°C ÷ +180°C)
	RINA: ELE139017CS004
	RUSSIAN MARINE CERTIFICATE (RMRS): 19.02521.280
	CCOE-PESO: P405709/1

Mechanical characteristics	
Body / cap	OT-58 marine brass (ON) - AISI-316L stainless steel (IX) marine grade copper free aluminium (on project request only)
Finishes	full nickel plating treatment (brass material only)
Rubber rings	EPDM rubber 50-60 shore hardness (standard supply) Silicon rubber 60 shore hardness (on demand only)
O-ring	silicon rubber - 60 shore hardness
Skid washer	nylon 6.0
Chamber for sealing	OT-58 marine brass ("R" version only)

Applications
For steel wire armoured cables (swa) for steel tape armoured cables
Single compression type for indoor and outdoor use
Provided armour clamping using clamping arrangements suitable for all armour wire/braid types
Single compression - under armour and overall of armour cable (inner and outer sealing)
Sealing with proper resin into "chamber of sealing" (on barrier type version "r" only)

On Request Accessories:

- Locknuts, Gaskets, PVC Shrouds, Earthing Tags, Sealing
  (See DL-NW-PTD-ET bulletin)

Cable gland selection table

CODE (1)	SIZE	ENTRY THREAD SIZE METRIC	(2)	NPT	(2)	ISO 228	(2)	DIA. UNDER ARMOUR min [mm]	DIA. UNDER ARMOUR max [mm]	OUTER SHEATH DIA. max [mm]	HEXAGON [mm]	MATERIAL	(3)
PA# PA-R#	00	**(16)ISO-M16 (0)3/8"**	**M**	**3/8"NPT**	**N**	**3/8"**	**G**	4,0	7,0	10,0	24,0	NICKEL PL.BRASS	ON
								7,0	10,0			STAINLESS STEEL	IX
		(20)ISO-M20 (1)1/2"		1/2"NPT		1/2"		5,5	8,0	10,0	32,0	NICKEL PL.BRASS	ON
								8,0	10,5	14,0		STAINLESS STEEL	IX
								10,5	13,0				
PA# PA-R#	01	ISO-M20	M	1/2"NPT	N	1/2"	G	5,5	8,0	13,0	32,0	NICKEL PL.BRASS	ON
								8,0	10,5			STAINLESS STEEL	IX
								10,5	13,0				
PA# PA-R#	02	ISO-M25	M	3/4"NPT	N	3/4"	G	10,5	13,0	18,0	36,0	NICKEL PL.BRASS	ON
								13,0	15,5			STAINLESS STEEL	IX
								15,5	18,0				
PA# PA-R#	03	ISO-M32	M	1"NPT	N	1"	G	15,0	18,0	24,0	45,0	NICKEL PL.BRASS	ON
								18,0	21,0			STAINLESS STEEL	IX
								21,0	24,0				
PA# PA-R#	04	ISO-M40	M	1 1/4"NPT	N	1 1/4"	G	21,0	24,0	30,0	53,0	NICKEL PL.BRASS	ON
								24,0	27,0			STAINLESS STEEL	IX
								27,0	30,0				
PA# PA-R#	05	ISO-M50	M	1 1/2"NPT	N	1 1/2"	G	24,0	27,0	36,0	61,0	NICKEL PL.BRASS	ON
								27,0	30,0				
								30,0	33,0			STAINLESS STEEL	IX
								33,0	36,0				
PA# PA-R#	06	ISO-M63	M	2"NPT	N	2"	G	36,0	39,0	45,0	71,0	NICKEL PL.BRASS	ON
								39,0	42,0				
								42,0	45,0			STAINLESS STEEL	IX
PA# PA-R#	07	ISO-M75	M	2 1/2"NPT	N	2 1/2"	G	42,0	45,0	54,0	84,0	NICKEL PL.BRASS	ON
								45,0	48,0				
								48,0	51,0			STAINLESS STEEL	IX
								51,0	54,0				
PA# PA-R#	08	ISO-M90	M	3"NPT	N	3"	G	52,0	56,0	68,0	101,0	NICKEL PL.BRASS	ON
								56,0	59,0				
								59,0	62,0			STAINLESS STEEL	IX
								62,0	65,0				
								65,0	68,0				
PA# PA-R#	09	ISO-M100	M	4"NPT	N	4"	G	68,0	74,0	92,0	126,0	NICKEL PL.BRASS	ON
								74,0	80,0				
								80,0	86,0			STAINLESS STEEL	IX
								86,0	92,0				

CABLE GLAND ORDERING EXAMPLES

PA#	01	M	ON	= **PA#01MON** (NON-BARRIER CABLE GLAND NICKEL PLATED BRASS ISO-M20 THR.)
PA#	03	N	IX	= **PA#03NIX** (NON-BARRIER CABLE GLAND STAINLESS STEEL 1"NPT THR.)

LEGEND

(1)	CABLE GLAND TYPE/MODEL	**PA**# = NON-BARRIER CABLE GLAND - **PA-R**# = BARRIER CABLE GLAND
(2)	THREADING	**M** = ISO METRIC pitch 1,5mm - **N** = NPT (ANSI/ASME B1.20.1) - **G** = ISO-228
(3)	CABLE GLAND MATERIAL	**ON** = NICKEL PLATED MARINE BRASS - **IX** = AISI-316L STAINLESS STEEL

PA DIMENSIONAL



* Chamber will be filled with sealing when cable gland is completely assembled.

1	BODY
2-3-4	INNER SEALING RING FOR ARMOURED CABLE
5	ARMOUR CLAMPING CONE
6	ARMOUR CLAMPING RING FOR ARMOURED CABL
7	ANTI RUBBING WASHER
8	GLAND NUT
9	O-RING (ONLY FOR METRICAL)
10	*CHAMBER FOR SEALING ("R" VERSION ONLY)

REMARK:
Due to the development of the national and international specifications and of the technology, the above technical characteristics showed on this bulletin can be considered as binding on our confirmation only.