

Certificate of Compliance

Issued to: BARTEC FEAM - ITALY

Certificate Number: SIR20200310-002

Dated: 10th March 2020

Equipment Tested: *PAP-PAP..R2 GLAND TYPE*

This is to certify that the glands identified in the attached report were wet deluge tested and are considered to comply with the relevant requirements of Shell DTS:01 "TEST SCHEDULE FOR ELECTRICAL EQUIPMENT TO BE INSTALLED IN AREAS SUBJECT TO WATER DELUGE SYSTEMS" as amended, August 1991.

SIRON Representative Signed:



P.O. Box 10280 7504 RG Enschede
t +31 53 750 30 44 f +31 53 750 30 45
www.siron.eu info@siron.eu

Lee Morgan – International Projects Manager

BARTEC FEAM Representative Signed:



F.E.A.M. S.r.l.

Mario Siano – R&D

